



GOVERNMENT OF ARUNACHAL PRADESH
DIRECTORATE OF FIRE & EMERGENCY SERVICES
ITANAGAR

Dated Itanagar, the 3rd April 2024

No.DIR/F&ES/RES-14(E)/MCES/2024

// PROVISIONAL FIRE SAFETY CERTIFICATE //

Certified that "Mount Carmel English School" Pasighat, District East Siang, Arunachal Pradesh was inspected by the officer concerned of this department on 15/03/2024 in the presence of the Principal, Mount Carmel English School, Pasighat and found that the said school have complied with the fire prevention and fire safety requirements in accordance with APBBL-2019. The premises is fit for Educational occupancy and hence issued a **Fire Safety Certificate for a period of 1 (one) year from the date of issue.**

This has the approval of Director, Fire & Emergency Services, Arunachal Pradesh.

Conditions for the validity of Fire Safety Certificate under:-

1. All Fire Protection Requirements Installed as per Educational Occupancy, Zone-I, Group-B (I) as specified in Annexure-B-I read with Chapter – 11 of APBBL-2019 must be in working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate should not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land, if any.
6. The owner/occupier shall apply for renewal of this certificate on **two months** prior to its expiry as per clause 11.3 of APBBL-2019 alongwith a copy of this Certificate.

To,

The Principal,
Mount Carmel English School,
Pasighat, District East Siang,
Arunachal Pradesh

(S. Chakraborty) APPS

Assistant Director
Fire & Emergency Services
A.P., Itanagar

Dated Itanagar, the 3rd April 2024

No.DIR/F&ES/RES-14(E)/MCES/2024

Copy to:

1. The Superintendent of Police, Pasighat, District East Siang, Arunachal Pradesh for information please.
2. The Officer In-charge, Fire Station, Pasighat for information.
3. Office copy.

Assistant Director
Fire & Emergency Services
A.P., Itanagar