

WATER QUALITY TEST REPORT OF MCES 15/03/2024)

Name of Source	Date of collection/ water sample test	Turbidity	pH value	Total Hardness mg/L	Total Iron mg/L	Chloride mg/L	Nitrate mg/L	Flouride mg/L	Sulphate mg/L	Total Alkanity mg/L	Bactriologic al Test
2	3	4	5	6	7	8	9	10	11	14	15
Ring Well	15-03-2024	0.37 NTU	6.75 mg/L	15 mg/L	0.15 mg/L	1.1 mg/L	0.216mg/L	0.60 mg/L	2 mg/L	35 mg/L	Neg-ve
le Range:-		5 NTU	6.5 - 8.5	200 mg/L	0.3 mg/L	200 mg/L	45.0 mg/L	1.5 mg/L	200 mg/L	200 mg/L	

Parameters are found normal


 Lab/Assistant
 PHE & W/S Sub - Division
 Pasighat


 Assistant Engineer
 PHE & W/S Sub - Division
 Pasighat
 15/3/24